



NOTES:

\*ICC-ES EVALUATION REPORT ESR-3032 ACCREDITED PRODUCT\*

MATERIAL:

COUPLER - STEEL, 40 KSI YIELD  
 PIPE - SHAFT STEEL, 50 KSI YIELD

WELDING REQUIREMENTS:

ALL WELDING TO BE PERFORMED BY WELDERS CERTIFIED  
 UNDER SECTION 5 OF AWS D1.1

FINISH:

HOT DIP GALVANIZED PER ASTM A123  
 HOT DIP GALVANIZED PER ASTM A153 (HDW)

DIMENSIONS: INCHES

HARDWARE:

HEX HEAD BOLT, 3/4 $\phi$  PER ASTM A325 (2 EA)  
 HEX JAM NUT, 3/4 $\phi$  PER ASTM A563 (2 EA)

MECHANICAL RATING:

ULTIMATE INSTALLATION TORQUE - 7,500 FT-LBS  
 ULTIMATE COMPRESSION RATING - 54,500 LBS  
 ULTIMATE TENSILE RATING - 40,000 LBS  
 K<sub>t</sub> FACTOR - 9

\*FOR RECOGNITION OF HIGHER LOAD VALUES THAN THOSE LISTED  
 ABOVE, BUT NOT EXCEEDING MACLEAN'S RECOMMENDED CAPACITIES  
 LISTED IN THE MACLEAN CIVIL PRODUCTS ENGINEERING MANUAL, A  
 SITE-SPECIFIC LOAD TEST IS RECOMMENDED TO BE PERFORMED  
 UNDER SUPERVISION OF A REGISTERING DESIGN PROFESSIONAL.

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to MacLean Power, L.L.C., Kingsley Park Five, 481 Munn Rd. Suite 300, Fort Mill, SC 29715, USA.



WWW.MACLEANPOWER.COM

CATALOG NUMBER:			P28E124
SHEET NAME:		Sheet1	1 OF 1
DRAWING DESCRIPTION:			EXTENSION BAR P28 2-7/8" X 124"
DRAWN BY:	DATE:	APPROVED:	
DH	03/09/20	DR	